



مختبرات ويمبي ش.ذ.م.م.  
WIMPEY LABORATORIES L.L.C.

**TEST REPORT**

|                    |   |                 |                  |
|--------------------|---|-----------------|------------------|
| Client             | Sabin Plastic Industries LLC<br>PO Box: 22185<br>Sharjah, UAE |                 |                  |
| Client Reference   | N.G   | Lab Report No.  | WD-R-220930-0528 |
| Consultant         | N.G   | Request No.     | WD-Q-220930-0147 |
| Project Name       | N.G   | Sample No.      | WD-S-220930-0485 |
| Sample Description | Plastic spacer- Wheel type 100mm HD                           | Wimpey Ref. No. | 22093017         |
| Source             | Sabin Plastic Industries LLC                                  | Date Received   | 30/09/2022       |
| Test Method        | In-House Procedure  | Date Tested     | 05/10/2022       |
| Test Temperature   | 23°C  | Date Reported   | 05/10/2022       |
| Relative Humidity  | 50%   | Tested By       | SI               |

**Test Result**

| Test      | Test Orientation | Load Applied (kN) | Load Applied (kg) | Observation     |
|-----------|------------------|-------------------|-------------------|-----------------|
| Load Test | Vertical         | 3.38              | 344.66            | Sample Deformed |

**Remarks:** Test photos with graph attached in Annexure A.

Signed for and on behalf of Wimpey Laboratories L.L.C.

**S. Sarath Kumar**  
Head of Department

Test results relate only to the samples tested.  
This report shall not be reproduced except in full, without the written approval of the laboratory.  
End of text-







مختبرات ويمبي ش.ذ.م.م.  
WIMPEY LABORATORIES L.L.C.

Report No. WD-R-220930-0528  
Sample No. WD-S-220930-0485

## ANNEXURE – A TEST PHOTOS



Graph

